



**NOTES**

1. DRAINER TO TEST ALL DRAINAGE AT DN150 I.O. WITH 150mm PLUG
2. ONCE TEST IS COMPLETED, REMOVE PLUG, DO NOT RE-ATTACH SCREW CAP INSTALL DN150 SHAFT TO SURFACE & FIT DN150 B.T.S. & SURROUND.
3. WHERE THE INSPECTION SHAFT OR BOUNDARY TRAP RISER IS LIKELY TO BE DAMAGED BY VEHICULAR TRAFFIC, THE CAP MAY BE INSTALLED BELOW SURFACE LEVEL. ACCESS SHALL BE PROVIDED IN ACCORDANCE WITH THE FOLLOWING:
  - a) A HEAVY-DUTY TRAFFICABLE COVER SHALL BE INSTALLED AT SURFACE LEVEL ABOVE AND INDEPENDENT OF THE CAP.
  - b) THE COVER SHALL BE SUITABLY SUPPORTED SO THAT NO LOAD CAN BE TRANSMITTED ONTO THE SHAFT.
  - c) THE SHAFT SHALL BE TERMINATED JUST BELOW THE UNDERSIDE OF THE COVER.
4. BOUNDARY KIT BOX SHALL BE LOCATED INSIDE THE PROPERTY BOUNDARY EITHER:
  - a) BESIDE EXISTING JUNCTION, OR
  - a) 600mm IN FROM FRONT BOUNDARY & 600mm FROM SIDE BOUNDARY.

**ELEVATION**  
**SINGLE HOUSEHOLD PUMP STATION RISING MAIN PROPERTY CONNECTION**  
 SCALE 1:10 (A3)

C	BOUNDARY KIT DETAILS AMENDED	S.K.J	03.2019
B	PLAN FORM UPGRADED & BOUNDARY KIT DETAILS AMENDED	G.P.C.	03.2014
A	ORIGINAL ISSUE	G.C.	11.2008
ISSUE	AMENDMENT DETAILS	INITIALS	DATE



**DESIGN UNIT**

COUNCIL OFFICES  
 TUMBULGUM ROAD,  
 MURWILLUMBAH,  
 NEW SOUTH WALES 2484  
 PHONE 02 6670 2400  
 FAX 02 6672 7513  
 WEBSITE www.tweed.nsw.gov.au

DESIGN ENGINEER	<i>[Signature]</i> DATE 04.03.2014
DESIGN MANAGER	<i>[Signature]</i> DATE 04.03.2014
DRAWN	ENGINEERING & OPERATIONS DESIGN UNIT
SCALE	AS SHOWN

PROJECT:	<b>SEWERAGE WORKS STANDARDS</b>
PLAN TITLE:	<b>PRESSURE SEWERAGE RISING MAIN CONNECTION OF SINGLE HOUSEHOLD PUMP TO COUNCIL GRAVITY SEWER</b>

DRAWING NUMBER:	<b>S.D.263</b>
	<b>MAR 2014</b>

ACAD FILE No: G:\\_AAA TSC STANDARD DRAWINGS\200 SEWERAGE WORKS\S.D.263 (Mar-14 Rev B).dwg

