




KERBED STREETS / ROADS
TYPICAL PAVEMENT MARKING PLAN FOR HYDRANTS
 (REFER TO NOTES)



TYPICAL KERB MARKING DETAIL



HYDRANT MARKER POST
FRONT ELEVATION



PAVEMENT MARKING FOR HYDRANTS

NOTES:

1. ALL HYDRANT KERB, PAVEMENT & BOX MARKINGS SHALL BE WHITE (TO AS2700 Y14 WHITE) WITH ONLY PAVEMENT AND KERB MARKING TO CONTAIN GLASS BEADS. PAVEMENT MARKING TO BE THERMOPLASTIC
2. MARKER POSTS SHALL ONLY BE USED IN STREETS AND ROADS WHERE THERE IS NO KERB & CHANNEL OR AS DIRECTED.
3. THE NOTICE PLATE SHALL BE REFLECTORIZED ALUMINIUM WITH BLACK LETTERING ON A WHITE BACKGROUND NOMINALLY 80mm x 80mm.
4. MARKER POSTS SHALL BE POSITIONED AT THE FRONT OF THE PROPERTY BOUNDARY OPPOSITE THE FITTING.
5. DIMENSIONS ARE IN MILLIMETRES UNLESS SHOWN OTHERWISE. BLUE DELINEATOR MARKER TO COMPLY WITH AS1906.3
6. BLUE DELINEATOR MARKER TO BE INSTALLED ON ROAD CENTRELINE
7. WHEN NO LINEMARKING OR RAISED PAVEMENT MARKERS EXIST.
8. BLUE DELINEATOR MARKER TO BE INSTALLED IN ACCORDANCE WITH THE MANUAL OF UNIFORM TRAFFIC CONTROL DEVICES WHEN LINE MARKING AND/OR RAISED PAVEMENT MARKERS EXIST.
9. REFER TO T.S.C. S.D.313 'FIRE HYDRANT INSTALLATION DETAILS'
10. SIMILAR MARKINGS, POSTS, ETC. MAY BE USED FOR STOP VALVES (SV), SCOUR VALVES (SCV) & AIR VALVES (AV) EXCEPT THAT BLUE DELINEATOR MARKERS SHALL NOT BE USED ON ROAD OR POSTS.
11. THE DISTANCE TO THE HYDRANT IN METRES, TO AN ACCURACY OF 0.1m, SHALL BE PERMANENTLY MARKED ON THE PLATE WITH LEGIBLE NUMBERS A MINIMUM OF 80mm HIGH - REFER TO T.S.C. CONSTRUCTION SPECIFICATION C401.41-2.

D	NOTES AMENDED & PLAN FORM UPGRADED	G.P.C.	06.2015
C	CALL OUTS & NOTE 10	G.P.C.	08.2010
B	HYDRANT MARKER POST, CALL OUT & NOTES 1 & 11	G.P.C.	05.2009
A	ORIGINAL ISSUE	G.P.C.	06.2006
ISSUE	AMENDMENT DETAILS	INITIALS	DATE



DESIGN UNIT
 COUNCIL OFFICES
 TUMBULGUM ROAD,
 MURWILLUMBAH,
 NEW SOUTH WALES 2464
 PHONE 02 6670 2400
 FAX 02 6672 7513
 WEBSITE www.tweed.nsw.gov.au

DESIGN ENGINEER	<i>Ahu</i>	DATE 11.05.15
DESIGN MANAGER	<i>P. May</i>	DATE 22.05.15
DRAWN	ENGINEERING & OPERATIONS DESIGN UNIT	
SCALE	AS SHOWN	

PROJECT:	WATER SUPPLY STANDARDS
PLAN TITLE:	MARKING FOR LOCATION OF HYDRANTS

DRAWING NUMBER:	S.D. 316
	JUNE 2015

0 10 20 30 40 50 100 150 200 250

ACAD FILE No: G:_AAA TSC STANDARD DRAWINGS\300 WATER SUPPLY\S.D.316 (June-15 Rev D).dwg