

WWTP Effluent Monitoring
Annual Summary
30/10/2023 to 29/10/2024



***Notes regarding Licence Limits**

A single number denotes a maximum value that should not be exceeded.
 Two numbers separated by a slash " / " denote a 90% limit and a maximum limit.
 Two numbers separated by a dash " - " denote minimum and maximum limits.

90 percentiles explained

Within a licence for each pollutant listed by the EPA, it will have a limit value. This value may be a 100 percentile limit where samples must meet the limit value 100% of the time. Lower limits may also be assigned.
 Where there are limit values lower than a 100% limit a sample or samples test results can exceed the limit value. For example, if a 90 percentile limit is assigned to a pollutant, this means 90% of collected samples should meet the limit value. If 10 samples are required in a year only one sample of the ten samples for the year is allowed to exceed the 90 percentile limit value. If more than one sample exceeds this value this would be a non-compliance of the licence conditions.

Treatment Plant: Mooball

EPA Licence Number: 20172

License Year: 30 October to 29 October

Monitoring Point: MoWWTP/Effluent EPA Point: Point 1

Summary Period 30/10/2023 to 29/10/2024	Pollutant	Units	Count	Min	Max	Mean	90% Value	Limits*	Exceed ance
Published: 06 Nov	Ammonia	mg/L	26	0.05	13.2	2.04	5.205	2 / 4	Yes
	BOD5	mg/L	26	<1.0	6.3	1.9	3.6	10 / 20	No
	Oil & Grease	mg/L	26	<2	2	2	0.0	5 / 10	No
	pH	pH units	26	7.0	7.5	7.2	7.3	6.5-8.5	No
	Suspended Solids	mg/L	26	<1.0	35.0	7.02	9.65	15 / 30	Yes
	Thermotolerant Coliforms	cfu/100 ml	26	<1	49	9	27.5	200 / 600	No
	Total Nitrogen	mg/L	26	1.94	18.2	6.63	12.0	10 / 20	Yes
	Total Phosphorus	mg/L	26	0.15	1.08	0.36	0.57	0.5 / 1	Yes