

**WWTP Effluent Monitoring**  
**Annual Summary**  
**12/12/2022 to 11/12/2023**



**\*Notes regarding Licence Limits**

A single number denotes a maximum value that should not be exceeded.  
 Two numbers separated by a slash " / " denote a 90% limit and a maximum limit.  
 Two numbers separated by a dash " - " denote minimum and maximum limits.

**90 percentiles explained**

Within a licence for each pollutant listed by the EPA, it will have a limit value. This value may be a 100 percentile limit where samples must meet the limit value 100% of the time. Lower limits may also be assigned.  
 Where there are limit values lower than a 100% limit a sample or samples test results can exceed the limit value. For example, if a 90 percentile limit is assigned to a pollutant, this means 90% of collected samples should meet the limit value. If 10 samples are required in a year only one sample of the ten samples for the year is allowed to exceed the 90 percentile limit value. If more than one sample exceeds this value this would be a non-compliance of the licence conditions.

**Treatment Plant: Uki**

**EPA Licence Number: 12392**

**License Year: 12 December to 11 December**

Monitoring Point: UWWTP/Effluent      EPA Point: Point 4

Summary Period	Pollutant	Units	Count	Min	Max	Mean	90% Value	Limits*	Exceedance
12/12/2022 to 11/12/2023  Published: 11 Dec	Ammonia	mg/L	25	0.03	0.51	0.21	0.37	5 / 10	No
	BOD5	mg/L	25	2.1	11.0	5.57	9.18	15 / 30	No
	Oil & Grease	mg/L	25	<2	2	2	0.0	10 / 20	No
	pH	pH units	25	6.9	7.7	7.22	7.46	6.5-8.5	No
	Suspended Solids	mg/L	25	<1.0	15.0	8.39	14.0	25 / 50	No
	Thermotolerant Coliforms	cfu/100ml	23	<1	4500	206	26.8	na	-
	Total Nitrogen	mg/L	25	2.72	5.09	3.92	4.76	30 / 60	No
	Total Phosphorus	mg/L	25	0.28	4.23	0.93	2.37	6 / 12	No