

WWTP Effluent Monitoring

Annual Summary

19/02/2020 to 18/02/2021



*Notes regarding Licence Limits

A single number denotes a maximum value that should not be exceeded.
 Two numbers separated by a slash " / " denote a 90% limit and a maximum limit.
 Two numbers separated by a dash " - " denote minimum and maximum limits.

90 percentiles explained

Within a licence for each pollutant listed by the EPA, it will have a limit value. This value may be a 100 percentile limit where samples must meet the limit value 100% of the time. Lower limits may also be assigned.
 Where there are limit values lower than a 100% limit a sample or samples test results can exceed the limit value. For example, if a 90 percentile limit is assigned to a pollutant, this means 90% of collected samples should meet the limit value. If 10 samples are required in a year only one sample of the ten samples for the year is allowed to exceed the 90 percentile limit value. If more than one sample exceeds this value this would be a non-compliance of the licence conditions.

Treatment Plant: Hastings Point

EPA Licence Number: 3618

License Year: 19 February to 18 February

Monitoring Point: HPWWTP/Effluent EPA Point: Point 1

Summary Period 19/02/2020 to 18/02/2021	Pollutant	Units	Count	Min	Max	Mean	90% Value	Limits*	Exceed ance
Published: 03 Mar	BOD5	mg/L	26	<1.0	11.0	2.53	6.2	10 / 20	No
	Oil & Grease	mg/L	26	<2	2	2	1.0	5 / 10	No
	pH	pH units	26	7.0	7.5	7.22	7.4	6.5-8.5	No
	Suspended Solids	mg/L	26	1.0	8.4	3.4	5.7	15 / 30	No
	Thermotolerant Coliforms	cfu/100 ml	26	<1	1110	49	35.0	na	-
	Total Nitrogen	mg/L	26	3.23	18.2	6.07	8.93	10 / 20	No
	Total Phosphorus	mg/L	26	0.16	0.96	0.29	0.455	1 / 2	No