

WWTP Effluent Monitoring

Annual Summary

31/03/2012 to 28/02/2025



*Notes regarding Licence Limits

A single number denotes a maximum value that should not be exceeded.

Two numbers separated by a slash " / " denote a 90% limit and a maximum limit.

Two numbers separated by a dash " - " denote minimum and maximum limits.

90 percentiles explained

Within a licence for each pollutant listed by the EPA, it will have a limit value. This value may be a 100 percentile limit where samples must meet the limit value 100% of the time. Lower limits may also be assigned.

Where there are limit values lower than a 100% limit a sample or samples test results can exceed the limit value. For example, if a 90 percentile limit is assigned to a pollutant, this means 90% of collected samples should meet the limit value. If 10 samples are required in a year only one sample of the ten samples for the year is allowed to exceed the 90 percentile limit value. If more than one sample exceeds this value this would be a non-compliance of the licence conditions.

Treatment Plant: Tyalgum

EPA Licence Number: 3470

License Year: 27 July to 26 July

Monitoring Point: TyWWTP/Effluent

EPA Point: Point 3

Summary Period	Pollutant	Units	Count	Min	Max	Mean	90% Value	Limits*	Exceedance
27/07/2011 to 26/07/2012 Published: 09 Aug	BOD5	mg/L	9	<1.0	14.0	3.61	8.08	25 / 40	No
	Oil & Grease	mg/L	9	<2	5	2	3.4	10	No
	Suspended Solids	mg/L	9	2.2	45.0	13.21	33.8	50 / 75	No
	Thermotolerant Coliforms	cfu/100 ml	9	<10	310	119	278.0	na	-
	Total Nitrogen	mg/L	9	2.12	3.44	2.58	2.968	na	-
	Total Phosphorus	mg/L	9	0.55	1.27	0.8	1.19	na	-
27/07/2012 to 26/07/2013 Published: 08 Aug	BOD5	mg/L	26	1.0	14.0	3.6	8.2	25 / 40	No
	Oil & Grease	mg/L	26	<2	<2	2	0.0	10	No
	Suspended Solids	mg/L	26	3.0	58.0	15.87	34.0	50 / 75	No
	Thermotolerant Coliforms	cfu/100 ml	26	5	940	272	620.0	na	-
	Total Nitrogen	mg/L	26	1.04	4.34	2.17	3.345	na	-
	Total Phosphorus	mg/L	26	0.38	3.31	1.62	3.285	na	-
27/07/2013 to 26/07/2014 Published: 12 Aug	BOD5	mg/L	26	<1.0	22.0	7.18	14.0	25 / 40	No
	Oil & Grease	mg/L	26	<2	4	2	1.5	10	No
	Suspended Solids	mg/L	26	14	72	34	57.0	50 / 75	Yes
	Thermotolerant Coliforms	cfu/100 ml	26	90	920	259	405.0	na	-
	Total Nitrogen	mg/L	26	1.89	5.28	3.5	4.75	na	-
	Total Phosphorus	mg/L	26	0.51	3.78	1.79	3.3	na	-

WWTP Effluent Monitoring

Annual Summary

31/03/2012 to 28/02/2025



Summary Period	Pollutant	Units	Count	Min	Max	Mean	90% Value	Limits*	Exceedance
27/07/2014 to 26/07/2015 Published: 06 Aug	BOD5	mg/L	26	3.0	26.0	9.7	18.5	25 / 40	No
	Oil & Grease	mg/L	26	<2.0	9.0	2.83	4.5	10	No
	Suspended Solids	mg/L	26	18	152	56	117.0	50 / 75	Yes
	Thermotolerant Coliforms	cfu/100 ml	26	<10	860	234	425.0	na	-
	Total Nitrogen	mg/L	26	1.53	5.81	2.96	4.955	na	-
	Total Phosphorus	mg/L	26	1.04	4.78	2.8	4.49	na	-
27/07/2015 to 26/07/2016 Published: 11 Aug	BOD5	mg/L	26	1.8	8.4	4.89	7.35	25 / 40	No
	Oil & Grease	mg/L	26	<2	5	2	2.5	10	No
	Suspended Solids	mg/L	26	5.8	49.0	22.12	38.0	50 / 75	No
	Thermotolerant Coliforms	cfu/100 ml	26	<10	6800	814	2070.0	na	-
	Total Nitrogen	mg/L	26	1.37	5.48	2.65	4.11	na	-
	Total Phosphorus	mg/L	26	0.5	2.65	1.62	2.34	na	-
27/07/2016 to 26/07/2017 Published: 02 Aug	BOD5	mg/L	26	2.4	15.9	8.69	12.0	25 / 40	No
	Oil & Grease	mg/L	26	<2	4	2	3.0	10	No
	Suspended Solids	mg/L	26	18.5	68.0	33.4	49.5	50 / 75	No
	Thermotolerant Coliforms	cfu/100 ml	26	50	2720	503	1275.0	na	-
	Total Nitrogen	mg/L	26	1.42	6.27	2.66	3.375	na	-
	Total Phosphorus	mg/L	26	0.36	4.3	1.92	3.795	na	-
27/07/2017 to 26/07/2018 Published: 01 Aug	BOD5	mg/L	26	<1.0	12.6	5.8	10.1	25 / 40	No
	Oil & Grease	mg/L	26	<2.0	3.4	2.21	3.0	10	No
	Suspended Solids	mg/L	26	6.3	51.0	27.41	43.0	50 / 75	No
	Thermotolerant Coliforms	cfu/100 ml	26	30	4500	576	1350.0	na	-
	Total Nitrogen	mg/L	26	1.63	6.65	3.33	5.04	na	-
	Total Phosphorus	mg/L	26	0.43	2.0	1.06	1.655	na	-

WWTP Effluent Monitoring

Annual Summary

31/03/2012 to 28/02/2025



Summary Period	Pollutant	Units	Count	Min	Max	Mean	90% Value	Limits*	Exceedance
27/07/2018 to 26/07/2019 Published: 12 Aug	BOD5	mg/L	26	2.0	21.9	8.96	15.8	25 / 40	No
	Oil & Grease	mg/L	26	<2.0	3.6	2.19	2.45	10	No
	Suspended Solids	mg/L	26	6.3	64.0	32.29	53.5	50 / 75	Yes
	Suspended Solids Corrected	mg/L	1	11.9	11.9	11.9	11.9	50 / 75	No
	Thermotolerant Coliforms	cfu/100 ml	26	10	2720	596	1424.0	na	-
	Total Nitrogen	mg/L	26	1.94	7.93	4.14	6.17	na	-
	Total Phosphorus	mg/L	26	0.7	3.16	1.73	2.66	na	-
27/07/2019 to 26/07/2020 Published: 12 Aug	BOD5	mg/L	26	3.6	33.0	13.3	21.0	25 / 40	No
	Oil & Grease	mg/L	26	<2	8	3	4.0	10	No
	Suspended Solids	mg/L	26	5.5	140.0	61.06	119.0	50 / 75	Yes
	Thermotolerant Coliforms	cfu/100 ml	26	40	2800	1057	2070.0	na	-
	Total Nitrogen	mg/L	26	1.64	7.78	4.55	7.0	na	-
	Total Phosphorus	mg/L	26	0.02	3.52	1.8	3.135	na	-
27/07/2020 to 26/07/2021 Published: 09 Aug	BOD5	mg/L	26	2.1	32.0	12.14	20.0	25 / 40	No
	Oil & Grease	mg/L	26	<2	5	3	4.0	10	No
	Suspended Solids	mg/L	26	15	110	52	86.0	50 / 75	Yes
	Thermotolerant Coliforms	cfu/100 ml	26	160	31000	2444	4650.0	na	-
	Total Nitrogen	mg/L	26	2.3	6.53	3.81	4.92	na	-
	Total Phosphorus	mg/L	26	0.24	2.35	1.09	1.505	na	-
27/07/2021 to 26/07/2022 Published: 07 Sep	BOD5	mg/L	26	<1.0	14.0	6.38	10.5	25 / 40	No
	Oil & Grease	mg/L	26	<2	3	2	2.0	10	No
	Suspended Solids	mg/L	26	4.6	59.0	29.87	49.5	50 / 75	No
	Thermotolerant Coliforms	cfu/100 ml	26	140	7080	1255	2300.0	na	-
	Total Nitrogen	mg/L	26	1.59	5.66	3.16	4.7	na	-
	Total Phosphorus	mg/L	26	0.08	0.95	0.46	0.905	na	-

WWTP Effluent Monitoring

Annual Summary

31/03/2012 to 28/02/2025



Summary Period	Pollutant	Units	Count	Min	Max	Mean	90% Value	Limits*	Exceedance
27/07/2022 to 26/07/2023 Published: 02 Aug	BOD5	mg/L	27	<1.0	25.0	7.39	14.0	25 / 40	No
	Oil & Grease	mg/L	27	<2	3	2	0.8	10	No
	Suspended Solids	mg/L	27	3.7	142.0	44.02	87.2	50 / 75	Yes
	Thermotolerant Coliforms	cfu/100 ml	26	4	5600	1332	3680.0	na	-
	Total Nitrogen	mg/L	27	1.72	7.67	3.36	5.632	na	-
	Total Phosphorus	mg/L	27	0.09	1.81	0.48	0.688	na	-
27/07/2023 to 26/07/2024 Published: 05 Aug	BOD5	mg/L	26	1.5	27.0	8.74	16.0	25 / 40	No
	Oil & Grease	mg/L	26	<2	3	2	1.0	10	No
	Suspended Solids	mg/L	26	4.5	106.0	36.65	85.5	50 / 75	Yes
	Thermotolerant Coliforms	cfu/100 ml	26	<20	28200	5617	14920.0	na	-
	Total Nitrogen	mg/L	26	1.67	10.8	3.84	5.54	na	-
	Total Phosphorus	mg/L	26	0.05	4.17	1.35	2.465	na	-
27/07/2024 to 26/07/2025 Published: 10 Feb	BOD5	mg/L	13	<1.0	16.0	4.8	7.74	25 / 40	No
	Oil & Grease	mg/L	13	<2	<2	<2	0.0	10	No
	Suspended Solids	mg/L	13	1.3	60.0	19.74	40.0	50 / 75	No
	Thermotolerant Coliforms	cfu/100 ml	13	400	43000000	3338143	239280.0	na	-
	Total Nitrogen	mg/L	13	1.59	6.81	3.79	6.258	na	-
	Total Phosphorus	mg/L	13	0.12	3.53	1.52	3.312	na	-