


- NOTES:
- REFER TO THE PIPEWORK SCHEDULE IN DWG S.D.220-06 FOR PIPEWORK DETAILS SHOWN THUS 1
 - ENSURE THAT ALL VALVES WITHIN THE VALVE PIT ARE ACCESSIBLE FROM ABOVE WITHOUT THE NEED TO REMOVE THE BEAM.
 - THE FLOWMETER IS TO BE LOCATED A MINIMUM DISTANCE OF 10 x DIAMETER OF THE MAIN FROM ANY UPSTREAM FITTING & A MINIMUM DISTANCE OF 5 x DIAMETER OF THE MAIN FROM ANY DOWNSTREAM FITTING & INSTALLED AS PER MANUFACTURER'S RECOMMENDATIONS.
 - THE ISOLATION VALVE IS TO BE LOCATED AT LEAST 5 x THE DIAMETER OF THE MAIN DOWNSTREAM OF THE FLOWMETER.



G	PUMP FLUSH VALVE REMOVED & ACCESS COVERS CLASS AMENDED	C.A.H.	05.2022
F	ACCESS COVERS TYPE AMENDED	J.M.M.	06.2021
E	ACCESS COVERS AMENDED	S.K.J	03.2019
D	REMOVED ACCESS LADDER AND AMENDED NOTES	S.K.J	03.2019
C	DROP PIPE ADDED TO INLET	A.K.R.	09.2015
B	PIPEWORK UPGRADED & NOTES AMENDED	G.P.C.	06.2015
A	ORIGINAL ISSUE (NEW SHEET - PREVIOUSLY PART OF S.D.220/03. FLOWMETER & NOTES ADDED)	G.P.C.	08.2014
ISSUE	AMENDMENT DETAILS	INITIALS	DATE



DESIGN UNIT
COUNCIL OFFICES
TUMBULGUM ROAD,
MURWILLUMBAH,
NEW SOUTH WALES 2484

PHONE 02 6670 2400
FAX 02 6672 7513
WEBSITE www.tweed.nsw.gov.au

DESIGN ENGINEER	<i>Adm</i>	DATE 14.09.15
DESIGN MANAGER	<i>Phy</i>	DATE 14.09.15
DRAWN	ENGINEERING & OPERATIONS DESIGN UNIT	
SCALE	1:40 (A3)	

PROJECT:	SEWERAGE WORKS STANDARDS	DRAWING NUMBER: S.D.220-04
PLAN TITLE:	2.0m DIAMETER PUMP STATION (SHEET 4 OF 6 SHEETS) SECTIONAL PLAN & SECTION 'A'	MAY 2022
ACAD FILE No: G:_AAA TSC STANDARD DRAWINGS\200 SEWERAGE WORKS\S.D.220-04 (May - 22 Rev G)		

